



Cindy Cox

AT&T South Carolina
1600 Williams Street
Suite 5470
Columbia, SC 29201

T: 803.401.2252
F: 803.771.4680
cc2283@att.com
www.att.com

215773

March 16, 2009

2006-188-C

Mr. Charles L. A. Terreni
Chief Clerk/Administrator
Public Service Commission of South Carolina
101 Executive Center Dr.
Columbia, South Carolina 29210

COPY
Posted: td
Dept: S.A.
Date: 3/17/09
Time: 3:10

RECEIVED
2009 MAR 16 PM 2:02
SC PUBLIC SERVICE
COMMISSION

Dear Mr. Terreni:

In compliance with Commission Rule 103-614, BellSouth Telecommunications, Inc. d/b/a AT&T South Carolina (AT&T) respectfully notifies the Public Service Commission of South Carolina ("the Commission") of service interruptions affecting the Barnwell and Greer areas by submitting the attached copies of the reports regarding these interruptions that AT&T submitted to the Federal Communications Commission ("FCC").

These reports contain information that is protected from public disclosure by Order No. 2006-777 that the Commission entered in Docket No. 2006-371-C on December 15, 2006. In compliance with that Order, AT&T is providing (1) proprietary, unredacted copy in a sealed envelope with each page marked in a manner calculated to alert custodians of the materials to their confidential or proprietary nature; and (2) a public copy of the information that redacts the specific information that is entitled to confidential and proprietary treatment.

As a courtesy, I am also providing a copy of this letter and copies of the redacted, public version of the report to the Office of Regulatory Staff.

If you have any questions, please contact me at 803-401-2252.

Yours very truly,

Executive Director

cc: Dawn Hipp, ORS

RECEIVED

MAR 17 2009

PSC SC
DOCKETING DEPT.



Proud Sponsor of the U.S. Olympic Team

SDRS Condensed Report

SDR #:	48495	SDR Ref #:	09-se00432
SDR Status:	Closed	<u>DETAILS</u>	<u>NARRATIVE</u>
Problem Description:	ALDLSCMARS1 and BRWLSCBERS1 remote switches isolated due to transport OC48 fiber issue in DNMKSCESRS1.		
SDR Type:	Transport	FYI:	No
SUB Type:	Fiber Jumper	PUC:	No
Scorecard Category:	Transport - IOF	FCC:	Yes
NRC Technology:	Transport - IOF NRC	Media:	No
Region:	Southeast	State:	SC
District:	Midlands/Low Country SC	City:	BARNWELL
Office CLLI:	BRWLSCBE	Office Name:	BARNWELL MA
Equipment CLLI:	RS1		
Direct Cause:	Procedural - System Vendor	Root Cause:	Procedural - Service Provider
Occurred Date:	02/26/09	Time:	10:45 (Eastern)
Estimated Restoral Date:		Time:	
Clear Date:	02/26/09	Time:	12:02 (Eastern)
GNOC Notify Date:	02/26/09	Time:	11:21 (Eastern)
Failure Duration:	77 minutes		
Equipment Category:		Equipment Vendor:	
Equipment Model:		Equipment Component:	
SDR Owner:	JOSEPH MORANSKI	Phone:	
Initiator:	JOSEPH MORANSKI	Phone:	
Customer Impact:	<div style="background-color: black; height: 20px; width: 100%;"></div> <div style="background-color: black; height: 20px; width: 100%;"></div> <div style="background-color: black; height: 20px; width: 100%;"></div> <div style="background-color: black; height: 20px; width: 100%;"></div>		
Event Narrative:	<div style="background-color: black; height: 100px; width: 100%;"></div>		

AT&T Proprietary (Internal Use Only)
Not for use or disclosure outside the AT&T companies
except under written agreement

Resolution Narrative:	
More Complete Description of Geographical Area:	

AT&T Proprietary (Internal Use Only)
Not for use or disclosure outside the AT&T companies
except under written agreement

SDRS Condensed Report

SDR #:	48620	SDR Ref #:	09-se00456
SDR Status:	Closed	<u>DETAILS</u>	<u>NARRATIVE</u>
Problem Description:	Snow storms caused power outages affecting multiple RTs in South Carolina.		
SDR Type:	Power	FYI:	No
SUB Type:	Backup	PUC:	No
Scorecard Category:	External Environment	FCC:	Yes
NRC Technology:	Transport - Access NRC	Media:	No
Region:	Southeast	State:	SC
District:	Upstate SC	City:	GREER
Office CLLI:	GRERSCMA	Office Name:	GREER
Equipment CLLI:			
Direct Cause:	Power Failure (Commercial and/or Back-up)	Root Cause:	Environment (External)
Occurred Date:	03/01/09	Time:	21:41 (Eastern)
Estimated Restoral Date:		Time:	
Clear Date:	03/03/09	Time:	15:29 (Eastern)
GNOC Notify Date:	03/02/09	Time:	01:02 (Eastern)
Failure Duration:	2,508 minutes		
Equipment Category:	Power	Equipment Vendor:	
Equipment Model:		Equipment Component:	
SDR Owner:	LAURINE HALLORAN	Phone:	
Initiator:	RICHARD DURAN	Phone:	
Customer Impact:			
Event Narrative:			
Resolution Narrative:			
More Complete Description of Geographical Area :			
AT&T Proprietary (Internal Use Only) Not for use or disclosure outside the AT&T companies except under written agreement			